

## NOAA MOC-P Fuel Tank Replacement

## Fuel Tank Questions and Answers

How much fuel is in the old tank?

The float level reads '7/8', so approximately 1750 gallons remain in the tank.

Is there an approximate weight on the old tank?

According to the owner's manual, the nominal weight of the tank was 30,000lbs.

Does any new piping have to be welded or can it be threaded?

The current set up has both welded and threaded fittings and hoses. I assume threaded is acceptable, but we may find requirements during permitting.

Do you have an example of the overfill alarm you're looking for? Something like the Morrison 918-0100AG Two-Inch Clock Gauge with Overfill Alarm and Standard Float

Was there an earthquake requirement on the base of the tank?

I can't find anything in our original plans. The brackets the old tank sits in do look like they may serve that purpose. I guess we will find out during permitting.

Do you have original install drawings or specs?

I can't find any original prints or specs from the first installation.

Background checks?

No Background checks will be required for this job. It will be short term, Port personnel will be on-hand while contractors are working. State IDs will be required at the gate to get in.

Who do you usually buy diesel fuel from?

Carson Oil - Diesel fuel supplier in Toledo, Oregon

Suggestion -

If you want to offer upgrade coatings, please list them as possible options on the bid. Given the environment we will seriously consider them.